

**North
Atlantic**

North Atlantic Energy Service Corporation
P.O. Box 300
Seabrook, NH 03874
(603) 474-9521

The Northeast Utilities System

DOCKET NUMBER
PROPOSED RULE **PR 50+52**
(67 FR 50374)

October 18, 2002
NYN-02107

DOCKETED
USNRC

October 29, 2002 (11:37AM)

Secretary
U. S. Nuclear Regulatory Commission
Mail Stop O-16C1
Washington, D. C. 20555-0001

OFFICE OF SECRETARY
RULEMAKINGS AND
ADJUDICATIONS STAFF

Seabrook Station

**Comments on the Notice of Proposed Rulemaking on 10 CFR 50.44,
Standards for Combustible Gas Control System in Light-Water-Cooled Power Reactors
(67 Fed. Reg. 50374, August 2, 2002)**


This letter provides the North Atlantic Energy Service Corporation (North Atlantic) response to the request for comment on the proposed rulemaking for 10 CFR 50.44, Standard for Combustible Gas Control System in Light-Water-Cooled Power Reactors. Notice of the opportunity to comment was published in the Federal Register (67 Fed. Reg. 50374).

North Atlantic has reviewed the comments submitted separately by the Nuclear Energy Institute (NEI) on behalf of the nuclear energy industry and endorses those comments. North Atlantic believes that the proposed rulemaking to eliminate the requirement for hydrogen recombiners and downgrade the equipment requirements for hydrogen and oxygen monitors and analyzers is an appropriate risk-informed initiative.

Thank you for the opportunity to comment on this important issue. If you have any questions regarding these comments, please contact me at (603) 773-7194.

Very truly yours,

NORTH ATLANTIC ENERGY SERVICE CORP.


James M. Peschel
Manager - Regulatory Programs

cc: H. J. Miller, NRC Region I Administrator
R.D. Starkey, NRC Project Manager, Project Directorate I-2
G.T. Dentel, NRC Senior Resident Inspector

Template = SECY-067

SECY-02